

**KEYED NOTES**

1. DEMOLISH CONDENSING UNIT AND CURB. PREPARE ROOF FOR INSTALLATION OF NEW UNIT AND CURB.
2. DEMOLISH REFRIGERANT PIPING AND ALL APPURTENANCES.
3. DEMOLISH RTU-R.6. MAINTAIN EXISTING CURB, DUCTWORK CONNECTIONS AND IN-CURB DUCT SILENCERS FOR REUSE WITH NEW UNIT.
4. DISCONNECT GAS PIPING FOR REMOVAL OF ROOFTOP UNIT. GAS PIPING TO REMAIN FOR CONNECTION TO NEW UNIT.

1 **MECHANICAL DEMOLITION ROOF PLAN** N  
 M1.3 SCALE: 1/8" = 1'-0"

**REVISIONS**

NO. DATE DESCRIPTION

ARCHITECTS PROJECT #

CLIENT PROJECT #

CLIENT ACCOUNT #

PROJECT TITLE

**CLACKAMAS COMMUNITY COLLEGE  
WILSONVILLE TRAINING CENTER  
RTU-6 REPLACEMENT**

SHEET TITLE

**MECHANICAL DEMOLITION  
ROOF PLAN**

SCALE  
1/8"=1'-0"DATE  
08-29-2022

SHEET NO.

**M1.3**